

Our Ref: P-25-AM0605

Date: 21/05/2026

FAO Aleks Aydin
Sovereign Network Group
The Hive,
22 Wembley Park Boulevard
London
HA9 0HP

Project Management
Cost Consultancy
Building Surveying
Procurement
CDM Services
Asset Management

To Whom It May Concern,

EWS1 and Fire Risk Appraisal of the External Wall (FRAEW) Report

Keegans have undertaken a Basic FRAEW in accordance with PAS9980:2022 Fire Risk Appraisal of External Wall Construction and Cladding of Existing Blocks of Flats - Code of Practice and subsequently completed an EWS1 form for Clavering Court, 1-13, The Ridgeway, Hertford, SG14 2FU.

The EWS1 form is based on the Valuation of Properties in Multi-Storey, Multi-Occupancy Residential Buildings with Cladding Guidance (April 2021), published by RICS.

- Masonry and Rainscreen (A) wall types contain combustible insulation.
- The building is **NOT** over four storeys,
- There are **NO** ACM, MCL or HPL panels present,
- There are vertically stacked balconies, and some of the materials are combustible,
- There were no serious cases of disrepair.

Upon assessing the building against 'Appendix B: EWS1 form decision tree', it can be concluded that an EWS1 form is not required. Keegans have completed an EWS1 form as requested by the client.

Due to the presence of combustible materials in the wall system and balconies, an 'A' EWS1 rating is not achievable.

Based on the PAS 9980:2022 methodology, the FRAEW concluded that the building achieves a Relative Risk Rating of 'Low Medium'; this is considered to be "sufficiently low", and the building does not require remedial works.

As such, the building achieves a 'B1' Rating.

Joe Wooding completed the FRAEW Report and EWS1 form. Chartered Surveyor member status with the Royal Institution of Chartered Surveyors and Fellow Chartered Building Engineer member status with the Chartered Association of Building Engineers. Joe is also an incorporated member of the Engineering Council and has completed the RICS Level 6 Award for External Wall System Assessment.

Yours sincerely,



.....
Joe Wooding BSc (Hons), MRICS, C.Build E FCABE, IEng

RICS Membership Number	1119586
CABE Membership Number	59514681
Engineering Council Membership Number	711457