

Our Ref: P-26 – AM0721

Date: 29 June 2026

FAO Aleks Aydin
Sovereign Network Group
The Hive,
22 Wembley Park Boulevard
London HA9 0HP

To Whom It May Concern,

EWS1 and Fire Risk Appraisal of the External Wall (FRAEW) Report

Keegans have undertaken a FRAEW in accordance with PAS9980:2022 Fire Risk Appraisal of External Wall Construction and Cladding of Existing Blocks of Flats – Code of Practice and subsequently completed an EWS1 form Denchworth House, 1-58, Robsart Street, London, SW9 0BN.

The EWS1 form is based on the Valuation of Properties in Multi-Storey, Multi-Occupancy Residential Buildings with Cladding Guidance (April 2021) published by RICS.

- The Wall Type 1: ETICS (including infill panels) contains combustible primary materials.
- The building is four storeys.
- There were no serious cases of disrepair.

Due to the presence of combustible materials in the wall system and balconies, an 'A' EWS1 rating is not achievable.

Based on the PAS 9980:2022 methodology, the FRAEW concluded that the building achieves a Relative Risk Rating of 'Low-Medium'; this is considered to be "sufficiently low", and the building does not require remedial works. As such, the building achieves a 'B1' Rating.

Rohan Coombs completed the FRAEW Report and EWS1 form. Rohan is a RICS Chartered Surveyor and a Member of the IFE. Rohan has also completed the RICS Level 6 Award for External Wall System Assessment.

Yours sincerely,

R. Coombs

Rohan Coombs MRICS MIFireE
Keegans Ltd

RICS Membership Number 6591473
IFE Membership Number 00078269
IFSM Membership Number 5527

thekeegansgroup.com

 N-Able Group
An N-able Group Company

Keegans Limited, Unit C, 65 Hopton Street, London, SE1 9LR.
T: 020 7199 0900 F: 0207 199 0901 E: info@thekeegansgroup.com
Regulated by RICS. Registered number: 04547050. Registered office: Unit C, 65 Hopton Street, London, SE1 9LR.