

PPG Laboratory Test Results Certification

Impact Resistance

PPG Industries, Inc. certifies the following performance properties for the DURANAR® Coil & Extrusion Coating Systems when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

Coatings:	DURANAR®
Test:	ASTM D2794-93 - Resistance of Organic Coatings to the Effects of Rapid Deformation (Impact)
Specification:	Factory painted sheet will withstand direct and reverse impact in accordance with ASTM D2794 equal to 3.0 X HDG metal thickness or 1.5 X aluminum metal thickness in mils, expressed in inch pounds.
Result:	No loss of adhesion when tested using Scotch brand 610 cellophane tape. Minute cracking at the perimeter of the impacted area is permissible.

