

# PPG Laboratory Test Results Certification

## Adhesion

PPG Industries, Inc. certifies the following performance properties for the DURANAR® Coil Coating Systems when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

|                       |  |
|-----------------------|--|
| <b>Coatings:</b>      | DURANAR® PLUS  |
| <b>Test:</b>          | ASTM D-3359 - Standard Test Methods for Measuring Adhesion by Tape Test  |
| <b>Specification:</b> | Test Method B - A lattice pattern with eleven cuts in each direction (90 degree to each other) is made in the film to the substrate. A reverse impact is applied 1.5 x metal thickness in mils to the cross-hatched area. Pressure sensitive #610 3M Scotch tape is applied over the reverse impacted lattice area and then removed rapidly. |
| <b>Result:</b>        | There shall be no flaking and no loss of adhesion of the topcoat and primer from the pretreated substrate, 5B classification.  |

