

PPG Laboratory Test Results Certification

Florida Exposure Chalk Resistance

PPG Industries, Inc. certifies the following performance properties for the DURANAR® Coil Coating Systems when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

Coatings:	DURANAR® XL PLUS
Test:	ASTM D4214 Test Method A-Method D 659: Evaluating Degree of Chalking of Exterior Paints
Specification:	Wrap black wool felt fabric around the index finger, then apply it with medium pressure to the film under observation. Rotate the finger through an angle of 180°, holding the fabric so it also rotates. Remove the fabric and compare the spot of chalk on it against the photographic reference standards.
Result:	After ten (10) years Florida exposure at 45° south, DURANAR® XLE will have a chalk rating of No. 10.

