

# PPG Laboratory Test Results Certification

## Florida Exposure Chalk Resistance

PPG Industries, Inc. certifies the following performance properties for the DURANAR® Coil & Extrusion Coating Systems when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

<b>Coatings:</b>	DURANAR®
<b>Test:</b>	ASTM D4214 Test Method A-Method D 659: Evaluating Degree of Chalking of Exterior Paints
<b>Specification:</b>	Wrap black wool felt fabric around the index finger, then apply it with medium pressure to the film under observation. Rotate the finger through an angle of 180°, holding the fabric so it also rotates. Remove the fabric and compare the spot of chalk on it against the photographic reference standards.
<b>Result:</b>	After ten (10) years Florida exposure at 45° south, DURANAR® will not chalk greater than No. 8 rating.

