

PPG Laboratory Test Results Certification

Mortar Resistance

PPG Industries, Inc. certifies the following performance properties for the DURANAR® Coil Coating Systems when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

Coatings: DURANAR® PLUS

Test: AAMA 2605-13, Section 8.7.2

Specification: Mortar mix is prepared in accordance with the AAMA 2605-13 specification. Test panel is coated with a 2 inch square pat and placed in a 100% relative humidity cabinet for 24 hours. The mortar is then dislodged and any residue is removed with a damp cloth.

Result: There will be no loss of coating film adhesion or visual change in appearance when examined by the unaided eye.

