Think about
Practical skills test
Level 3 Fire, Emergency and
Security Systems Technician APO2 –
Option - Fire



On the day of assessment, you will carry out:



A 2-day practical skills test consisting of 4 practical tasks using addressable and non-addressable systems



Face-to-face at an assessment centre



In a simulated environment



With an end-point assessor



You will be given tasks that you must demonstrate in a simulated environment. Unsatisfactory performance in either of the following two safety-critical areas will result in a mandatory fail and the termination of the assessment:

- isolation of mains electricity when undertaking any activity it is best practice to ask permission or verbalise that the supply is being turned off
- · the identification of, and working with, a viable loop circuit

Do
Review the criteria associated with the practical skills test – this
can be found in the EPA kit
Review relevant legislation, regulations and your organisation's
policies and procedures and safe working practices
Use the planner to record key points to remember in order to
meet the required criteria associated with the practical skills test
Ensure you demonstrate the two safety critical areas

	Ensure you are confident with both addressable
	and non-addressable systems
	Carry out a mock assessment of a takeover and installation
	with your employer or training provider
Ty.	Don't
	Forget to bring your ID Bring any of your own tools or equipment – everything you need
	will be supplied for you



Next steps

- Results can take up to 12 working days to be confirmed
- Your manager/training provider will inform you of the results




Resits

 If you do not achieve a pass result on the practical skills test you can reattempt the assessment



Key point

If you fail in either of the safety-critical areas, you will need to have a performance review before you go through gateway for one further attempt at the end-point assessment.



Standard area - Core	Key points to remember
Working safely	
Core systems techniques	
System technologies	
Supervisory	
Standard Area – Option Fire	

V1: Nov 2021 (AP02)

www.highfield.co.uk

© 2021 Highfield Awarding Body of Compliance Limited