

PPG Laboratory Test Results Certification

Florida Exposure Color Retention

PPG Industries, Inc. certifies the following performance properties for the DURANAR® Coil Coating System when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

Coatings:	DURANAR
Test:	ASTM-D2244 - Calculation of Color differences from Instrumentally Measured Color Coordinates.
Specification:	The difference in color between a reference and a test specimen is determined from measurements made with a spectrophotometer or a colorimeter. Reflectance readings from these instruments are converted by computations to color-scale values. Color-difference magnitudes are computed, from differences in color-scale values, which represent the perceived color differences between the reference and the test specimen.
Result:	After ten (10) years Florida exposure at 45° south DURANAR® will not fade more than five (5) delta E Hunter color units.

