

# PPG Laboratory Test Results Certification

## Impact Resistance

PPG Industries, Inc. certifies the following performance properties for the DURANAR® Coil Coating System when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

|                       |                                                                                                                                                                                                      |
|-----------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Coatings:</b>      | DURANAR                                                                                                                                                                                              |
| <b>Test:</b>          | ASTM D2794-93 - Resistance of Organic Coatings to the Effects of Rapid Deformation (Impact).                                                                                                         |
| <b>Specification:</b> | Factory painted sheet will withstand direct and reverse impact in accordance with ASTM D2794 equal to 3.0 X HDG metal thickness or 1.5 X aluminum metal thickness in mils, expressed in inch pounds. |
| <b>Result:</b>        | No loss of adhesion when tested using Scotch brand 610 cellophane tape. Minute cracking at the perimeter of the impacted area is permissible.                                                        |

